Environmental and Laboratory Services

Dover Location:
90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Analytical Results

Date: March 31, 2022
Client: Jefferson Township BOE
Address: 31 NJ-181
Lake Hopatcong, NJ 07849

PWSID#:
Project Location: 1 Jefferson Drive, Lake Hopatcong

Sample Matrix: Drinking Water
Sample Location: Field Blank
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:20

Lab Sample Number: 211026038-001
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	3/25/2022	15:49	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-POE-KC-HWS-1
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:21

Lab Sample Number: 211026038-002
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	3/25/2022	15:54	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-FP-KC-SINK -2
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:22

Lab Sample Number: 211026038-003
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.02	µg/L	15	3/25/2022	16:00	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-WF-HALL BY KITCHEN-3
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:23

Lab Sample Number: 211026038-004
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	3/25/2022	16:05	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-WC-HALL-CHILD STUDY TEAM-4
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:24

Lab Sample Number: 211026038-005
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	3/25/2022	16:11	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DW-RM101-5
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:25

Lab Sample Number: 211026038-006
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	9.99	µg/L	15	3/25/2022	16:16	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-WF-RM102-6
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:26

Lab Sample Number: 211026038-007
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	17.4 **	µg/L	15	3/25/2022	16:22	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-WF-RM106-7
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:27

Lab Sample Number: 211026038-008
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	5.58	µg/L	15	3/25/2022	16:27	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-WF-BY NS-8
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:28

Lab Sample Number: 211026038-009
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	10.2	µg/L	15	3/25/2022	16:50	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-NS-SINK-1-9
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:29

Lab Sample Number: 211026038-010
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.47	µg/L	15	3/25/2022	16:55	JGW	2	1

Sample Matrix: Drinking Water
Lab Sample Number: 211026038-011
Sample Location: JTBE-NS-BATHROOM SINK-2-10
Customer Sample Number:
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:30

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.51	µg/L	15	3/25/2022	17:01	JGW	2	1

Sample Matrix: Drinking Water
Lab Sample Number: 211026038-012
Sample Location: JTBE-DWB-RM109-11
Customer Sample Number:
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:31

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	8.14	µg/L	15	3/25/2022	17:07	JGW	2	1

Sample Matrix: Drinking Water
Lab Sample Number: 211026038-013
Sample Location: JTBE-DW-RM109-12
Customer Sample Number:
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:32

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	5.26	µg/L	15	3/25/2022	17:12	JGW	2	1

Sample Matrix: Drinking Water
Lab Sample Number: 211026038-015
Sample Location: JTBE-DW-RM110-14
Customer Sample Number:
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:34

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	17.8 **	µg/L	15	3/25/2022	17:17	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DWB-RM120-15
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:35

Lab Sample Number: 211026038-016
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	13.4	µg/L	15	3/25/2022	17:23	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DW-RM120-16
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:36

Lab Sample Number: 211026038-017
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	4.66	µg/L	15	3/25/2022	17:29	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DWB-RM121-17
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:37

Lab Sample Number: 211026038-018
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	9.80	µg/L	15	3/25/2022	17:34	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DW-RM121-18
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:38

Lab Sample Number: 211026038-019
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	7.36	µg/L	15	3/25/2022	17:40	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DWB-RM122-19
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:39

Lab Sample Number: 211026038-020
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.62	µg/L	15	3/25/2022	18:29	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DW-RM122-20
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:40

Lab Sample Number: 211026038-021
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	3/25/2022	18:35	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DWB-RM123-21
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:41

Lab Sample Number: 211026038-022
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.36	µg/L	15	3/25/2022	18:40	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DW-RM123-22
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:42

Lab Sample Number: 211026038-023
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	3/25/2022	18:45	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DWB-RM124-23
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:43

Lab Sample Number: 211026038-024
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	8.64	µg/L	15	3/25/2022	18:51	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DW-RM124-24
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:44

Lab Sample Number: 211026038-025
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	7.78	µg/L	15	3/25/2022	18:56	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DW-RM111-26
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:46

Lab Sample Number: 211026038-027
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	5.90	µg/L	15	3/25/2022	19:02	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DWB-RM113-27
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:47

Lab Sample Number: 211026038-028
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	15.2 **	µg/L	15	3/25/2022	19:07	JGW	2	1

ple Matrix: Drinking Water
Sample Location: JTBE-DW-RM113-28
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:48

Lab Sample Number: 211026038-029
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.77	µg/L	15	3/25/2022	19:30	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DWB-RM112-29
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:49

Lab Sample Number: 211026038-030
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	18.8 **	µg/L	15	3/22/2022	17:02	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DW-RM112-30
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:50

Lab Sample Number: 211026038-031
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	5.12	µg/L	15	3/25/2022	19:35	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DWB-RM114-31
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:51

Lab Sample Number: 211026038-032
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	6.49	µg/L	15	3/25/2022	19:41	JGW	2	1

ple Matrix: Drinking Water
Sample Location: JTBE-DW-RM114-32
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:52

Lab Sample Number: 211026038-033
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	5.74	µg/L	15	3/25/2022	19:47	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DWB-RM115-33
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:53

Lab Sample Number: 211026038-034
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	11.4	µg/L	15	3/25/2022	19:53	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DW-RM115-34
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:54

Lab Sample Number: 211026038-035
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	3/25/2022	19:58	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DWB-RM117-35
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:55

Lab Sample Number: 211026038-036
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	3/25/2022	20:04	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DW-RM117-36
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:56

Lab Sample Number: 211026038-037
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	3/25/2022	20:09	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DWB-RM119-37
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:57

Lab Sample Number: 211026038-038
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	12.1	µg/L	15	3/25/2022	20:15	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DW-RM119-38
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:58

Lab Sample Number: 211026038-039
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	7.49	µg/L	15	3/25/2022	20:21	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DWB-RM118-39
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 6:59

Lab Sample Number: 211026038-040
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	8.92	µg/L	15	3/25/2022	21:11	JGW	2	1

ple Matrix: Drinking Water
Sample Location: JTBE-DW-RM118-40
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 7:00

Lab Sample Number: 211026038-041
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	5.17	µg/L	15	3/25/2022	21:17	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DWB-RM116-41
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 7:01

Lab Sample Number: 211026038-042
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	2.45	µg/L	15	3/25/2022	21:23	JGW	2	1

Sample Matrix: Drinking Water
Sample Location: JTBE-DW-RM116-42
Sampled By: A. Mooney
Sample Date/Time: 3/16/2022 7:02

Lab Sample Number: 211026038-043
Customer Sample Number:

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	22.7 **	µg/L	15	3/25/2022	21:31	JGW	2	1

NJ Lab ID# 14013 (Dover)
NJ Lab ID# 13033 (Marlboro)

** Result does not meet NJDEP Limits.
NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.
Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.
All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I[illegible]fy that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen
Susan VanVeen, Laboratory Manager

March 31, 2022

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

211026038

Customer Name:	Jefferson Township BOE	Report to: Jefferson Township BOE	Agra Environmental Services
Location:	1 Jefferson Drive, Lake Hopatcong	31 NJ-181	90 ½ West Blackwell Street
Address:	31 NJ-181	Lake Hopatcong, NJ, 07849	Dover, NJ 07801
	Lake Hopatcong, NJ, 07849	jjahnke@jefftwp.org	Phone: (973) 989-0010
Customer Contact:	Nick		Fax: (973) 989-0156
Phone: Work/Cell	973-663-5780 / 973-214-6997		

#	Asc./HCl Vials	pH:	
#	HCl Vials	pH:	
#	$Na_2S_2O_3$	Cl_2:	
#	HNO_3	pH:	
#	H_2SO_4	pH:	
#	NaOH	pH:	
#	unpreserved		
#	other		
#	other		

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Project: Ellen T. Briggs Elementary Collection PWSID#

for laboratory use only

Field Analysis

Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl_2 or PO_4
211026038-001	Field Blank	3/16/22	0600	X		DW	1	HNO3	Lead-1st Draw		
211026038-002	JTBE-POE-KC-HWS-1		0621	X		DW	1	HNO3	Lead-1st Draw		
211026038-003	JTBE-FP-KC-SINK -2		0622	X		DW	1	HNO3	Lead-1st Draw		
211026038-004	JTBE-WF-HALL BY KITCHEN-3		0623	X		DW	1	HNO3	Lead-1st Draw		
211026038-005	JTBE-WC-HALL-CHILD STUDY TE		0624	X		DW	1	HNO3	Lead-1st Draw		
211026038-006	JTBE-DW-RM101-5		0625	X		DW	1	HNO3	Lead-1st Draw		
211026038-007	JTBE-WF-RM102-6		0626	X		DW	1	HNO3	Lead-1st Draw		
211026038-008	JTBE-WF-RM106-7		0627	X		DW	1	HNO3	Lead-1st Draw		
211026038-009	JTBE-WF-BY NS-8		0628	X		DW	1	HNO3	Lead-1st Draw		
211026038-010	JTBE-NS-SINK-1-9		0629	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): Jadren A / Agra

Are these samples for compliance? (circle one): Yes or (No)

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis request was performed

Cooler Temperature Upon Receipt at lab: 0.6°C

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date:	Time:	Received By:	Date:	Time:
[signature]	3/16/22	1215	[signature]	3/16/22	1240

Comments: * pres. w/ HNO3 @ lab 3/16/22 1230

Date Faxed _____

Invoice Number _____

Is sample known to be hazardous? (circle one) Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

211026038

Customer Name:	Jefferson Township BOE	Report to: Jefferson Township BOE	Agra Environmental Services
Location:	1 Jefferson Drive, Lake Hopatcong	31 NJ-181	90 ½ West Blackwell Street
Address:	31 NJ-181	Lake Hopatcong, NJ, 07849	Dover, NJ 07801
	Lake Hopatcong, NJ, 07849	jjahnke@jefftwp.org	Phone: (973) 989-0010
Customer Contact:	Nick		Fax: (973) 989-0156
Phone: Work/Cell	973-663-5780 / 973-214-6997		

#	Asc./HCl Vials	pH:
#	HCl Vials	pH:
#	$Na_2S_2O_3$	Cl_2:
#	HNO_3	pH:
#	H_2SO_4	pH:
#	NaOH	pH:
#	unpreserved	
#	other	
#	other	

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Project: Ellen T. Briggs Elementary Collection PWSID#

for laboratory use only

Field Analysis

Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl_2 or PO_4
211026038-011	JTBE-NS-BATHROOM SINK-2-10	3/16/22	0630	X		DW	1	HNO3	Lead-1st Draw		
211026038-012	JTBE-DWB-RM109-11		0631	X		DW	1	HNO3	Lead-1st Draw		
211026038-013	JTBE-DW-RM109-12		0632	X		DW	1	HNO3	Lead-1st Draw		
~~211026038-014~~	~~JTBE-DWB-RM110-13~~ Shut off		~~0633~~	X		DW	1	HNO3	Lead-1st Draw No sample		
211026038-015	JTBE-DW-RM110-14		0634	X		DW	1	HNO3	Lead-1st Draw		
211026038-016	JTBE-DWB-RM120-15		0635	X		DW	1	HNO3	Lead-1st Draw		
211026038-017	JTBE-DW-RM120-16		0636	X		DW	1	HNO3	Lead-1st Draw		
211026038-018	JTBE-DWB-RM121-17		0637	X		DW	1	HNO3	Lead-1st Draw		
211026038-019	JTBE-DW-RM121-18		0638	X		DW	1	HNO3	Lead-1st Draw		
211026038-020	JTBE-DWB-RM122-19		0639	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): Andrew M. Agra

Are these samples for compliance? (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Indicate laboratory location where analysis request was performed

Cooler Temperature Upon Receipt at lab: 0.6°C

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date:	Time:	Received By:	Date:	Time:
[signature]	3/16/22	1215	[signature]	3/16/22	1220
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:

Comments: Rm 110 DWB was shut off

Date Faxed _____

Invoice Number _____

Is sample known to be hazardous? (circle one) Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

211026038

Customer Name:	Jefferson Township BOE	Report to: Jefferson Township BOE	Agra Environmental Services
Location:	1 Jefferson Drive, Lake Hopatcong	31 NJ-181	90 ½ West Blackwell Street
Address:	31 NJ-181	Lake Hopatcong, NJ, 07849	Dover, NJ 07801
	Lake Hopatcong, NJ, 07849	jjahnke@jefftwp.org	Phone: (973) 989-0010
Customer Contact:	Nick		Fax: (973) 989-0156
Phone: Work/Cell	973-663-5780 / 973-214-6997		

#	Asc./HCl Vials	pH:	
#	HCl Vials	pH:	
#	$Na_2S_2O_3$	Cl_2:	
# 2	HNO_3	pH:	
#	H_2SO_4	pH:	
#	NaOH	pH:	
#	unpreserved		
#	other		
#	other		

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Project: Ellen T. Briggs Elementary Collection PWSID#

for laboratory use only

Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Field Analysis Cl_2 or PO_4
211026038-021	JTBE-DW-RM122-20	3/16/22	0640	X		DW	1	HNO3	Lead-1st Draw		
211026038-022	JTBE-DWB-RM123-21		0641	X		DW	1	HNO3	Lead-1st Draw		
211026038-023	JTBE-DW-RM123-22		0642	X		DW	1	HNO3	Lead-1st Draw		
211026038-024	JTBE-DWB-RM124-23		0643	X		DW	1	HNO3	Lead-1st Draw		
211026038-025	JTBE-DW-RM124-24		0644	X		DW	1	HNO3	Lead-1st Draw		
211026038-026	~~JTBE-DWB-RM111-25~~ Removed		~~0645~~	X		DW	1	HNO3	Lead-1st Draw No Sample		
211026038-027	JTBE-DW-RM111-26		0646	X		DW	1	HNO3	Lead-1st Draw		
211026038-028	JTBE-DWB-RM113-27		0647	X		DW	1	HNO3	Lead-1st Draw		
211026038-029	JTBE-DW-RM113-28		0648	X		DW	1	HNO3	Lead-1st Draw		
211026038-030	JTBE-DWB-RM112-29		0649	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): Andrew M / Agra

Are these samples for compliance? (circle one): Yes or No

Indicate laboratory location where analysis request was performed

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Cooler Temperature Upon Receipt at lab: 0.6°C

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Sample Custody Exchanges (Please use full legal signature)

Comments: RM 111 DWB was removed

Relinquished By:	Date:	Time:	Received By:	Date:	Time:
[signature]	3/16/22	1215	[signature]	3/16/22	1240

Date Faxed _____

Invoice Number _____

Is sample known to be hazardous? (circle one) Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

211026038

Customer Name:	Jefferson Township BOE	Report to: Jefferson Township BOE	Agra Environmental Services
Location:	1 Jefferson Drive, Lake Hopatcong	31 NJ-181	90 ½ West Blackwell Street
Address:	31 NJ-181	Lake Hopatcong, NJ, 07849	Dover, NJ 07801
	Lake Hopatcong, NJ, 07849	jjahnke@jefftwp.org	Phone: (973) 989-0010
Customer Contact:	Nick		Fax: (973) 989-0156
Phone: Work/Cell	973-663-5780 / 973-214-6997		

#	Asc./HCl Vials	pH:	
#	HCl Vials	pH:	
#	$Na_2S_2O_3$	Cl_2:	
# 10	HNO_3	pH:	
#	H_2SO_4	pH:	
#	NaOH	pH:	
#	unpreserved		
#	other		
#	other		

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Project: Ellen T. Briggs Elementary Collection PWSID#

for laboratory use only

Field Analysis

Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl_2 or PO_4
211026038-031	JTBE-DW-RM112-30	3/16/22	0650	X		DW	1	HNO3	Lead-1st Draw		
211026038-032	JTBE-DWB-RM114-31		0651	X		DW	1	HNO3	Lead-1st Draw		
211026038-033	JTBE-DW-RM114-32		0652	X		DW	1	HNO3	Lead-1st Draw		
211026038-034	JTBE-DWB-RM115-33		0653	X		DW	1	HNO3	Lead-1st Draw		
211026038-035	JTBE-DW-RM115-34		0654	X		DW	1	HNO3	Lead-1st Draw		
211026038-036	JTBE-DWB-RM117-35		0655	X		DW	1	HNO3	Lead-1st Draw		
211026038-037	JTBE-DW-RM117-36		0656	X		DW	1	HNO3	Lead-1st Draw		
211026038-038	JTBE-DWB-RM119-37		0657	X		DW	1	HNO3	Lead-1st Draw		
211026038-039	JTBE-DW-RM119-38		0658	X		DW	1	HNO3	Lead-1st Draw		
211026038-040	JTBE-DWB-RM118-39		0659	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): Tom / Andrew M.

Are these samples for compliance? (circle one): Yes or (No)

Indicate laboratory location where analysis request was performed

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Cooler Temperature Upon Receipt at lab: 0.6°C

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Sample Custody Exchanges (Please use full legal signature)

Comments:

Relinquished By:	Date:	Time:	Received By:	Date:	Time:
[signature]	3/16/22	1215	[signature]	3/16/22	1240

Date Faxed _____

Invoice Number _____

Is sample known to be hazardous? (circle one) Yes or No

CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

211026038

Customer Name:	Jefferson Township BOE	Report to: Jefferson Township BOE	Agra Environmental Services
Location:	1 Jefferson Drive, Lake Hopatcong	31 NJ-181	90 ½ West Blackwell Street
Address:	31 NJ-181	Lake Hopatcong, NJ, 07849	Dover, NJ 07801
	Lake Hopatcong, NJ, 07849	jjahnke@jefftwp.org	Phone: (973) 989-0010
Customer Contact:	Nick		Fax: (973) 989-0156
Phone: Work/Cell	973-663-5780 / 973-214-6997		

#	Asc./HCl Vials	pH:	
#	HCl Vials	pH:	
#	$Na_2S_2O_3$	Cl_2:	
# 5	HNO_3	pH:	
#	H_2SO_4	pH:	
#	NaOH	pH:	
#	unpreserved		
#	other		
#	other		

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Project: Ellen T. Briggs Elementary Collection PWSID# for laboratory use only Field Analysis

Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl_2 or PO_4
211026038-041	JTBE-DW-RM118-40	3/16/22	0700	X		DW	1	HNO3	Lead-1st Draw		
211026038-042	JTBE-DWB-RM116-41	/	0701	X		DW	1	HNO3	Lead-1st Draw		
211026038-043	JTBE-DW-RM116-42	/	0702	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): Andrew M. / Agra

Are these samples for compliance? (circle one): Yes or No

Indicate laboratory location where analysis request was performed

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Cooler Temperature Upon Receipt at lab: 0.6°C

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Sample Custody Exchanges (Please use full legal signature)

Comments:

Relinquished By:	Date:	Time:	Received By:	Date:	Time:
[signature]	3/16/22	1215	[signature]	3/16/22	1240

Date Faxed _____

Invoice Number _____

Is sample known to be hazardous? (circle one) Yes or No